

BGE
STRATEGIC CUSTOMER ENGINEERING

SUBMITTAL REQUIREMENTS
PRIMARY SERVICE CUSTOMERS

BGECSR-SUBMITTALS -REVISION No.3 – DECEMBER, 2006

This information page details most of the requirements necessary for customers' who want to be or are supplied at BGE's primary service voltages (13 kV or 33 kV). Whether you are installing new service entrance equipment, adding to existing service or modernizing an existing service we want to guide you through the process. For a complete detailing of these requirements, the following BGE specifications are available:

- CSR-1, METAL-ENCLOSED SWITCHGEAR (SWITCH AND FUSE STYLE)
- CSR-2, METAL-CLAD (CIRCUIT BREAKER STYLE)
- CSR-3, OPEN BUS STATIONS
- CSR-4, NETWORK CONNECTED PRIMARY SUBSTATIONS
- CSR-5, LOW VOLTAGE AUTOMATIC TRANSFER OPTIONS
- CSR-6, CONNECTION OF GENERATION
- CSR-7, RE-ENERGIZING PRIMARY SERVICE SUBSTATIONS

Please note:

- A "Service Application Agreement" must be completed before any work is started by BGE
- All documents are available upon request or through www.bge.com and then look under the tab "**Business Customers**"

The following is a list of required documents that must be submitted for review and approval by BGE:

1. Drawing Submittals

- 1.1. Site Drawing: Details the location of the service on the customer's site. This shall include any electrical ducts that may be required and any underground obstructions
- 1.2. Grounding Drawing: Details the ground grid for the substation and how it connects to the equipment and fencing
- 1.3. One-Line Wiring Diagram: Details the electrical system to be installed from the point of BGE's service entrance through the first transformation

2. Coordination Study

- 2.1. This document will show how the customer's overcurrent devices (fuses or circuit breakers) will coordinate with the BGE system.
- 2.2. System design information and fault currents are available upon request

BGE
STRATEGIC CUSTOMER ENGINEERING

SUBMITTAL REQUIREMENTS
PRIMARY SERVICE CUSTOMERS

BGECSR-SUBMITTALS -REVISION No.3 – DECEMBER, 2006

3. Manufacturer’s Shop drawings

- 3.1. These drawings will detail the equipment manufacturer’s design. This shall include all service entrance equipment and transformers.
- 3.2. For 33 kV transformers a manufacturer’s certified test shall be provide showing the impedance of the individual units

In addition to these above submittals the following documents must be submitted for review and approval prior to arranging the physical cut-in of the equipment:

4. Certified Test Report

This is a document produced by an independent test agency that will test the equipment to insure that it is electrically safe to energize. This shall include but not limited to hi-pot test, insulation resistance test, ground resistance test, etc. Please see the appropriate CSR document for additional information.

5. Certificate of Electrical Inspection

This is the document issued by the local inspection authority that authorizes the energization of equipment. For State and Federal government locations a “Statement of Exemption to local Authority” may be submitted.

- 5.1. A letter from the local jurisdiction to BGE or the property owner stating that they are waiving electrical inspection is required for all properties except those owned by the State of Maryland. This letter must specifically state the property’s address.

6. Access Notification

This document details customer personnel and telephone numbers that BGE may use to contact the customer as necessary for normal and emergency switching operations.